

Dense Well-Graded Sand, Sand and Gravel with an Internal Angle of Friction (Φ) = 34°

Wall Loading Condtion	Design		Minimum		Minimum		Max. Exposed Wall Height	
	Height ft (m)		Bury Depth		Leveling Pad			•
		(m)	ft	(m)	ft	(m)	ft	(m)
NO BACKSLOPE	2.0	(0.610)	0.5	(0.152)	0.5	(0.152)	1.5	(0.457)
NO SURCHARGE	2.5	(0.762)	0.5	(0.152)	0.5	(0.152)	2.0	(0.610)
	3.0	(0.914)	0.5	(0.152)	0.5	(0.152)	2.5	(0.762)
	3.5	(1.067)	0.5	(0.152)	0.5	(0.152)	3.0	(0.914)
Max. Exposed Wall Height	4.0	(1.219)	0.5	(0.152)	0.5	(0.152)	3.5	(1.067)
Wall Height (Varies)	4.5	(1.372)	0.5	(0.152)	0.5	(0.152)	4.0	(1.219)
Ψ-S+	5.0	(1.524)	0.5	(0.152)	0.5	(0.152)	4.5	(1.372)
	5.5	(1.676)	0.5	(0.152)	0.5	(0.152)	5.0	(1.524)
	6.0	(1.829)	0.5	(0.152)	0.5	(0.152)	5.5	(1.676)
_Minimum Leveling Pad	6.5	(1.981)	0.5	(0.152)	0.5	(0.152)	6.0	(1.829)
Bury Depth (Varies) (Varies)								
(varios)								
NO BACKSLOPE	2.0	(0.610)	0.5	(0.152)	0.5	(0.152)	1.5	(0.457)
100 psf (4.79 kPa) LIVE LOAD SURCHARGE	2.5	(0.762)	0.5	(0.152)	0.5	(0.152)	2.0	(0.610)
(Light Traffic)	3.0	(0.914)	0.5	(0.152)	0.5	(0.152)	2.5	(0.762)
Max. Exposed 100 psf (4.79 kPa) Wall Height	3.5	(1.067)	0.5	(0.152)	0.5	(0.152)	3.0	(0.914)
(Varies)	4.0	(1.219)	0.5	(0.152)	0.5	(0.152)	3.5	(1.067)
	4.5	(1.372)	0.5	(0.152)	0.5	(0.152)	4.0	(1.219)
	5.0	(1.572)	0.5	(0.152)	0.5	(0.152)	4.5	(1.372)
φ = 34°	5.5	` '	0.5	(0.152)	0.5	` ′	5.0	(1.524)
	5.5	(1.676)	0.5	(0.152)	0.5	(0.152)	5.0	(1.524)
Minimum Leveling Pad								
Bury Depth (Varies) (Varies)								
(
• 1:2.5 (21.8°) BACKSLOPE	2.0	(0.610)	0.5	(0.152)	0.5	(0.152)	1.5	(0.457)
NO SURCHARGE	2.5	(0.762)	0.5	(0.152)	0.5	(0.152)	2.0	(0.610)
Max. Exposed	3.0	(0.914)	0.5	(0.152)	0.5	(0.152)	2.5	(0.762)
Wall Height (Varies)	3.5	(1.067)	0.5	(0.152)	0.5	(0.152)	3.0	(0.914)
2.5	4.0	(1.219)	0.5	(0.152)	0.5	(0.152)	3.5	(1.067)
	4.5	(1.372)	0.5	(0.152)	0.5	(0.152)	4.0	(1.219)
1 - 040	5.0	(1.524)	0.5	(0.152)	0.5	(0.152)	4.5	(1.372)
φ = 34°	5.5	(1.676)	0.5	(0.152)	0.5	(0.152)	5.0	(1.524)
Minimum Leveling Pad								
Bury Depth (Varies)								
(Varies)								

<u>NOTES</u> The above chart was prepared by Rosetta® Hardscapes LLC for estimating and conceptual design purposes only. All information is believed to be true and accurate, however, Rosetta® Hardscapes LLC assumes no responsibility for the use of these design charts for actual construction. Determination of the suitability of each chart is the sole responsibility of the user. <u>Final designs for construction purposes must be performed by a registered Professional Engineer</u>, using the actual conditions of the proposed site.

- 1. Unit weight of 28°, 30°, 34° and 40° soils is assumed to be 120 pcf (18.9 kN/m³).
- 2. Minimum factors of safety are 1.5 for sliding, 1.5 for overturning and 2.0 for bearing capacity.
- 3. Designs are in general accordance with NCMA's <u>Design Manual for Segmental Retaining Walls (2nd ed.)</u>.
- ${\bf 4. \ Global \ stability \ has \ not \ been \ addressed \ in \ these \ charts.}$
- 5. The wall design shall address both internal and external drainage and shall be evaluated by the Professional Engineer who is responsible for the final wall design.
- 6. Backfill material to be compacted to 95% standard proctor.
- 7. All Rosetta® Hardscapes LLC Wall System Specifications are to be followed.
- 8. Block sizes and placement shown for reference only. Individual Rosetta® Hardscapes blocks will vary with installation pattern.



Silty Sand, Fine to Medium Sand with an Internal Angle of Friction (Φ) = 30°

Wall Loading Condtion	Wall Loading Condtion Design Height		Minimum Bury Depth		Minimum Leveling Pad		Max. Exposed Wall Height	
	ft	eigrit (m)	ft Bury	/ Deptn (m)	ft	iing Pad (m)	ft	неідпі (m)
NO BACKSLOPE	2.0	(0.610)	0.5	(0.152)	0.5	(0.152)	1.5	(0.457)
NO SURCHARGE	2.5	(0.762)	0.5	(0.152)	0.5	(0.152)	2.0	(0.610)
NO CONCINUED	3.0	(0.914)	0.5	(0.152)	0.5	(0.152)	2.5	(0.762)
	3.5	(1.067)	0.5	(0.152)	0.5	(0.152)	3.0	(0.914)
<u> </u>	4.0	(1.219)	0.5	(0.152)	0.5	(0.152)	3.5	(1.067)
Max. Exposed Wall Height	4.5	(1.372)	0.5	(0.152)	0.5	(0.152)	4.0	(1.219)
(Varies) $\phi = 30^{\circ}$	5.0	(1.524)	0.5	(0.152)	0.5	(0.152)	4.5	(1.372)
	5.5	(1.676)	0.5	(0.152)	0.5	(0.152)	5.0	(1.524)
	6.0	(1.829)	0.5	(0.152)	0.5	(0.152)	5.5	(1.676)
	0.0	(1.020)	0.0	(0.102)	0.0	(0.102)	0.0	(1.0.0)
Minimum └── Minimum Leveling Pad Bury Depth (Varies)								
(Varies)								
NO BACKSLOPE	2.0	(0.610)	0.5	(0.152)	0.5	(0.152)	1.5	(0.457)
• 100 psf (4.79 kPa) LIVE LOAD SURCHARGE	2.5	(0.762)	0.5	(0.152)	0.5	(0.152)	2.0	(0.610)
(Light Traffic)	3.0	(0.914)	0.5	(0.152)	0.5	(0.152)	2.5	(0.762)
Max. Exposed 100 psf (4.79 kPa)	3.5	(1.067)	0.5	(0.152)	0.5	(0.152)	3.0	(0.914)
(Varies)	4.0	(1.219)	0.5	(0.152)	0.5	(0.152)	3.5	(1.067)
	4.5	(1.372)	0.5	(0.152)	0.5	(0.152)	4.0	(1.219)
		,		,				· · ·
φ = 30°								
Minimum └── Minimum Leveling Pad Bury Depth (Varies)								
(Varies)								
• 1:2.5 (21.8°) BACKSLOPE	2.0	(0.610)	0.5	(0.152)	0.5	(0.152)	1.5	(0.457)
NO SURCHARGE	2.5	(0.762)	0.5	(0.152)	0.5	(0.152)	2.0	(0.610)
Max. Exposed	3.0	(0.914)	0.5	(0.152)	0.5	(0.152)	2.5	(0.762)
Wall Height 1	3.5	(1.067)	0.5	(0.152)	0.5	(0.152)	3.0	(0.914)
(Varies) 2.5	4.0	(1.219)	0.5	(0.152)	0.5	(0.152)	3.5	(1.067)
	4.5	(1.372)	0.5	(0.152)	0.5	(0.152)	4.0	(1.219)
$\phi = 30^{\circ}$								
1 202000								
Minimum Leveling Pad								
Bury Depth (Varies)								
(Varies) ´ ´								

<u>NOTES</u> The above chart was prepared by Rosetta® Hardscapes LLC for estimating and conceptual design purposes only. All information is believed to be true and accurate, however, Rosetta® Hardscapes LLC assumes no responsibility for the use of these design charts for actual construction. Determination of the suitability of each chart is the sole responsibility of the user. <u>Final designs for construction purposes must be performed by a registered Professional Engineer</u>, using the actual conditions of the proposed site.

- 1. Unit weight of 28°, 30°, 34° and 40° soils is assumed to be 120 pcf (18.9 kN/m 3).
- 2. Minimum factors of safety are 1.5 for sliding, 1.5 for overturning and 2.0 for bearing capacity.
- 3. Designs are in general accordance with NCMA's <u>Design Manual for Segmental Retaining Walls (2nd ed.)</u>.
- 4. Global stability has not been addressed in these charts.
- 5. The wall design shall address both internal and external drainage and shall be evaluated by the Professional Engineer who is responsible for the final wall design.
- 6. Backfill material to be compacted to 95% standard proctor.
- 7. All Rosetta® Hardscapes LLC Wall System Specifications are to be followed.
- 8. Block sizes and placement shown for reference only. Individual Rosetta® Hardscapes blocks will vary with installation pattern.



Silty Sand, Clayey Sand with an Internal Angle of Friction (Φ) = 28°

Wall Loading Condtion		Design		Minimum		Minimum		Max. Exposed	
	Height		Bury Depth		Leveling Pad		Wall Height		
	ft	(m)	ft	(m)	ft	(m)	ft	(m)	
NO BACKSLOPE	2.0	(0.610)	0.5	(0.152)	0.5	(0.152)	1.5	(0.457)	
NO SURCHARGE	2.5	(0.762)	0.5	(0.152)	0.5	(0.152)	2.0	(0.610)	
	3.0	(0.914)	0.5	(0.152)	0.5	(0.152)	2.5	(0.762)	
	3.5	(1.067)	0.5	(0.152)	0.5	(0.152)	3.0	(0.914)	
Max. Exposed	4.0	(1.219)	0.5	(0.152)	0.5	(0.152)	3.5	(1.067)	
Wall Height (Varies) $\phi = 28^{\circ}$	4.5	(1.372)	0.5	(0.152)	0.5	(0.152)	4.0	(1.219)	
Ψ – 28	5.0	(1.524)	0.5	(0.152)	0.5	(0.152)	4.5	(1.372)	
	5.5	(1.676)	0.5	(0.152)	0.5	(0.152)	5.0	(1.524)	
Minimum Leveling Pad									
Bury Depth (Varies)									
(Varies)									
NO BACKSLOPE	2.0	(0.610)	0.5	(0.152)	0.5	(0.152)	1.5	(0.457)	
100 psf (4.79 kPa) LIVE LOAD SURCHARGE	2.5	(0.762)	0.5	(0.152)	0.5	(0.152)	2.0	(0.610)	
(Light Traffic)	3.0	(0.914)	0.5	(0.152)	0.5	(0.152)	2.5	(0.762)	
Max. Exposed 100 psf (4.79 kPa) Wall Height	3.5	(1.067)	0.5	(0.152)	0.5	(0.152)	3.0	(0.914)	
(Varies)	4.0	(1.219)	0.5	(0.152)	0.5	(0.152)	3.5	(1.067)	
	1.0	(1.210)	0.0	(0.102)	0.0	(0.102)	0.0	(1.001)	
φ = 28°									
Minimum									
Bury Depth (Varies) (Varies)									
	0.0	(0.010)	0.5	(0.450)	0.5	(0.450)	4 -	(0.477)	
• 1:2.5 (21.8°) BACKSLOPE	2.0	(0.610)	0.5	(0.152)	0.5	(0.152)	1.5	(0.457)	
NO SURCHARGE	2.5	(0.762)	0.5	(0.152)	0.5	(0.152)	2.0	(0.610)	
Max. Exposed Wall Height 1	3.0	(0.914)	0.5	(0.152)	0.5	(0.152)	2.5	(0.762)	
(Varies)	3.5	(1.067)	0.5	(0.152)	0.5	(0.152)	3.0	(0.914)	
2.5	4.0	(1.219)	0.5	(0.152)	0.5	(0.152)	3.5	(1.067)	
1 – 000									
φ = 28°									
Minimum Loyoling Rod									
Bury Depth (Varies)									
(varies)									
Minimum									

<u>NOTES</u> The above chart was prepared by Rosetta® Hardscapes LLC for estimating and conceptual design purposes only. All information is believed to be true and accurate, however, Rosetta® Hardscapes LLC assumes no responsibility for the use of these design charts for actual construction. Determination of the suitability of each chart is the sole responsibility of the user. <u>Final designs for construction purposes must be performed by a registered Professional Engineer</u>, using the actual conditions of the proposed site.

- 1. Unit weight of 28°, 30°, 34° and 40° soils is assumed to be 120 pcf (18.9 kN/m³).
- 2. Minimum factors of safety are 1.5 for sliding, 1.5 for overturning and 2.0 for bearing capacity.
- 3. Designs are in general accordance with NCMA's <u>Design Manual for Segmental Retaining Walls (2nd ed.)</u>.
- 4. Global stability has not been addressed in these charts.
- 5. The wall design shall address both internal and external drainage and shall be evaluated by the Professional Engineer who is responsible for the final wall design.
- 6. Backfill material to be compacted to 95% standard proctor.
- 7. All Rosetta® Hardscapes LLC Wall System Specifications are to be followed.
- 8. Block sizes and placement shown for reference only. Individual Rosetta® Hardscapes blocks will vary with installation pattern.



Crushed Stone Backfill with (ϕ) = 40° Over Native Soil with (ϕ) = 28°

Wall Loading Condtion	Design Height		Minimun Bury Dep		Minimum Leveling Pad		Max. Exposed Wall Height	
	ft	(m)	ft	/ Беріп (m)	ft	(m)	ft	(m)
NO BACKSLOPE	2.0	(0.610)	0.5	(0.152)	0.5	(0.152)	1.5	(0.457)
NO SURCHARGE	2.5	(0.762)	0.5	(0.152)	0.5	(0.152)	2.0	(0.610)
■ ■■888888888888	3.0	(0.914)	0.5	(0.152)	0.5	(0.152)	2.5	(0.762)
	3.5	(1.067)	0.5	(0.152)	0.5	(0.152)	3.0	(0.914)
Max. Exposed $\phi = 40^{\circ}$	4.0	(1.219)	0.5	(0.152)	0.5	(0.152)	3.5	(1.067)
Wall Height	4.5	(1.372)	0.5	(0.152)	0.5	(0.152)	4.0	(1.219)
(Varies) $\phi = 28^{\circ}$	5.0	(1.524)	0.5	(0.152)	0.5	(0.152)	4.5	(1.372)
	5.5	(1.676)	0.5	(0.152)	0.5	(0.152)	5.0	(1.524)
	6.0	(1.829)	0.5	(0.152)	0.5	(0.152)	5.5	(1.676)
	6.5	(1.981)	0.5	(0.152)	0.5	(0.152)	6.0	(1.829)
Minimum	7.0	(2.134)	0.5	(0.152)	1.0	(0.305)	6.5	(1.981)
(Varies)								
NO BACKSLOPE	2.0	(0.610)	0.5	(0.152)	0.5	(0.152)	1.5	(0.457)
 100 psf (4.79 kPa) LIVE 	2.5	(0.762)	0.5	(0.152)	0.5	(0.152)	2.0	(0.610)
LOAD SURCHARGE 100 psf (4.79 kPa) (Light Traffic)	3.0	(0.914)	0.5	(0.152)	0.5	(0.152)	2.5	(0.762)
HI#3 200000000	3.5	(1.067)	0.5	(0.152)	0.5	(0.152)	3.0	(0.914)
φ = 40°	4.0	(1.219)	0.5	(0.152)	0.5	(0.152)	3.5	(1.067)
Max. Exposed Wall Height	4.5	(1.372)	0.5	(0.152)	0.5	(0.152)	4.0	(1.219)
(Varies) $\phi = 28^{\circ}$	5.0	(1.524)	0.5	(0.152)	0.5	(0.152)	4.5	(1.372)
	5.5	(1.676)	0.5	(0.152)	0.5	(0.152)	5.0	(1.524)
1	6.0	(1.829)	0.5	(0.152)	1.0	(0.305)	5.5	(1.676)
	6.5	(1.981)	0.5	(0.152)	1.0	(0.305)	6.0	(1.829)
Minimum └── Minimum Leveling Pad Bury Depth (Varies)								
(Varies)								
• 1:2.5 (21.8°) BACKSLOPE	2.0	(0.610)	0.5	(0.152)	0.5	(0.152)	1.5	(0.457)
NO SURCHARGE 1	2.5	(0.762)	0.5	(0.152)	0.5	(0.152)	2.0	(0.610)
2.5	3.0	(0.914)	0.5	(0.152)	0.5	(0.152)	2.5	(0.762)
	3.5	(1.067)	0.5	(0.152)	0.5	(0.152)	3.0	(0.914)
φ = 40°	4.0	(1.219)	0.5	(0.152)	0.5	(0.152)	3.5	(1.067)
Wall Height	4.5	(1.372)	0.5	(0.152)	0.5	(0.152)	4.0	(1.219)
(Varies) φ = 28°	5.0	(1.524)	0.5	(0.152)	0.5	(0.152)	4.5	(1.372)
	5.5	(1.676)	0.5	(0.152)	1.0	(0.305)	5.0	(1.524)
1	6.0	(1.829)	0.75	(0.229)	0.5	(0.152)	5.25	(1.600)
Minimum	6.5	(1.981)	1.0	(0.305)	0.5	(0.152)	5.5	(1.676)
Minimum └── Minimum Leveling Pad Bury Depth (Varies)								
(Varies)								

<u>NOTES</u> The above chart was prepared by Rosetta® Hardscapes LLC for estimating and conceptual design purposes only. All information is believed to be true and accurate, however, Rosetta® Hardscapes LLC assumes no responsibility for the use of these design charts for actual construction. Determination of the suitability of each chart is the sole responsibility of the user. <u>Final designs for construction purposes must be performed by a registered Professional Engineer</u>, using the actual conditions of the proposed site.

- 1. Unit weight of 28°, 30°, 34° and 40° soils is assumed to be 120 pcf (18.9 kN/m³).
- 2. Minimum factors of safety are 1.5 for sliding, 1.5 for overturning and 2.0 for bearing capacity.
- 3. Designs are in general accordance with NCMA's <u>Design Manual for Segmental Retaining Walls (2nd ed.)</u>.
- 4. Global stability has not been addressed in these charts.
- 5. The wall design shall address both internal and external drainage and shall be evaluated by the Professional Engineer who is responsible for the final wall design.
- 6. Backfill material to be compacted to 95% standard proctor.
- 7. All Rosetta® Hardscapes LLC Wall System Specifications are to be followed.
- 8. Block sizes and placement shown for reference only. Individual Rosetta® Hardscapes blocks will vary with installation pattern.